



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 6/29/09

Code 50.9-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition
Section number and title R506.2.3 Vapor retarder		Page 1 of 1
Proponent Craig Wagner	Title Chief Building Inspector/ IABO Code Comm. Member	
Address 220 W Van Buren St, Columbia City IN 46725		Phone 260-248-3111
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Change Items 2. and 3. in the exception as follows:</p> <p>2. For unheated storage rooms having an area of less than 70 square feet (6.5 m²) and carports.</p> <p>3. From <u>carports</u>, driveways, walks...</p> <p>Renumber items in exception.</p>		
REASON AND FISCAL IMPACT		
<p>This proposal removes an allowance for rooms of 70 square feet or less in area from the requirement for a vapor retarder under a concrete slab because the definition of the room is too vague and does not state whether the room is inside the thermal envelope or not; if inside the thermal envelope the issue of a damp slab and increased heat transfer still remain.</p> <p>Fiscal impact: there is no increase to the cost of construction.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		